

الجنة الجنية لمتطلبات الخنية Safety Technical Committee

Ref. No.: HSE/1251/2013 Date: 15/04/2013

Subject: Prequalification with Kahramaa for Fire Rated Steel Door

We refer to your letter BQ/KAHRAMAA/035/2012 dated 21.10.2012 enclosing the submittals for prequalification of "Vulcan fire rated steel doors" with Kahramaa. After reviewing the documents, Kahramaa Safety Committee hereby grants approval to Vulcan Industries LLC manufactured fire rated steel doors with below specifications;

Fire Rated Steel Door Types

- 1. Vulcan Single & Double Steel Flush Doors Set
- 2. Vulcan Single & Double Vision Door Set
- 3. Vulcan Single Steel Transom Panel Door Set
- 4. Vulcan Double Steel Transom Panel Door Set
- 5. Vulcan Single Steel Side Transom Door Set
- 6. Vulcan Double Steel Side Transom Door Set

Door Specifications:

Single / pair of swinging steel stiffened hollow metal type fire doors intended for 3 hours

Door Sizes = 2200 mm (Width) X 2400 mm (Height)

2400 mm can be over-panel (Transom panel) and over the width of 2200 mm can be Side Panel which should not be more than the width of single shutter size

Ironmongery / Hardware Details:

1.5 Hot deep galvanized sheet used for frame supply by Jindal / AlGurail

1.2mm Hot deep galvanized sheet used for leaf supplied by Jindal / AlGurail

3mm mild steel used for reinforcement supplied by Gentex

 Honeycomb 0.43mm thick, 32mm cell size used inside the door supplied by honeycell

materia

Tel: (+974) 44845577/5575 . Fax: (+974) 44845595 - P.O. Box: 41 Doha - Quiur

www.km.com.qa

الفسال better living



الجنة الجنية الجنية المائمة Safety Technical Committee

SR. NO	HARDWARE	BRAND	CODE
i i	Hinges (102 x 102 x 3 mm)	Devon	89:339.86
2	Mortise Latch Lock	Consort	CH 7251F
3	Solid Lever Handle	Consort	CH900 =====
4	Flush Bolt	Consort	CH2820.8 & 9
3.4	Dust Excluding Socket	Consort	CDS 75
6	Double Profile Cylinder	Consort	CH780.2
7	Push Bar	Consort	CPH6080F
8	External Access Device	Consort	CP649

Please note that KAHRAMAA Safety Committee approval is only for above mentioned fire rated steel doors with specified hardware and is valid for 2 years from date of approval letter. Any noncompliance to specifications or information submitted during prequalification may lead to automatic withdrawal of this approval and disqualification of the company.

Regards

Eng. A. Robinson All M. Nasma Head of Safety Technical Committee KAHRAMAA

Initial:

Mary I.C.

